

Utah Department of Environmental Quality

Division of Drinking Water

Monitoring Schedule

Run Date:
08/04/2011 12:10 pm

PWS ID: UTAH14009 **Name:** MEADOW TOWN WATER SYSTEM

Legal Contact: MEADOW **Rating:** Approved
TERRILL LYNN BOND **Rating Date:** 02/01/1985

Address: PO BOX 42 **Activity Status:** Active
MEADOW, UT 84644

Phone Number: 435-406-9013

City Served (Area):

County: MILLARD COUNTY

System Type: Community **Last Inv Update:** 06/13/2011 **Avg Daily Prod:**

Activity Status Cd: Active **Last Snty Srv Dt:** 06/23/2008 **Total Dsgn Cap:**

Population: 260 **Surveyor:** WADE TOLBERT **Total Emerg Cap:**

Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Total Coliform Rule Monitoring

Sample Count	Sample Type	Sample Frequency	Effective Begin Date	Effective End Date	Seasonal Start	Seasonal End	Analyte Name
1	Routine	Monthly	10/01/2007		1/1	12/31	COLIFORM (TCR)

Additional Monitoring Requirements

(The Sample Label is not correct for Disinfection Byproducts, TOC, TOC Alkalinity, and any triggered groundwater samples)

Facility ☐ ID Facility Name

Analyte Name	Sample Count	Sample Type	Sample Frequency	Last Sample	Next Sample Between
DS001 UTAH14009 DISTRIBUTION SYSTEM			Activity Status: A	Sample Label: UTAH14009 DS001	
Disinfection Biproducts	1	Routine	3 Years	09/21/2010	07/01-09/30 2013
Lead & Copper	10	Routine	6 Months	2010	06/01-09/30
Disinfection Biproducts	1	Routine	3 Years	09/21/2010	07/01-09/30 2013
SS162 GROUP SOURCE SAMPLING STATION SS162			Activity Status: A	Sample Label: UTAH14009 SS162 SS162	
NITRATE	1	Routine	Year	09/21/2010	01/01/2011-12/31/2011
Radionuclides	1	Routine	9 Years	12/23/2002	01/01/2011-12/31/2019
Inorg & Metals	1	Routine	3 Years	09/21/2010	01/01/2011-12/31/2013
Sodium,Sulfate,TDS	1	Routine	3 Years	09/21/2010	01/01/2011-12/31/2013
Volatile Organics	1	Routine	6 Years	09/21/2010	01/01/2014-12/31/2019
WS006 EAST WELL			Activity Status: A	Sample Label: UTAH14009 WS006 WS006	
NITRATE	1	Routine	Year	09/21/2010	01/01/2011-12/31/2011
Volatile Organics	1	Routine	Year	09/21/2010	01/01/2011-12/31/2011
Inorg & Metals	1	Routine	3 Years	09/21/2010	01/01/2011-12/31/2013
Sodium,Sulfate,TDS	1	Routine	3 Years	09/21/2010	01/01/2011-12/31/2013
Radionuclides	1	Routine	3 Years	11/11/2008	01/01/2011-12/31/2013

Sources Grouped for Sampling Compliance

Source Group ID: UTAH SAMPLING STATION SS162

Sources in Group

WS001	CARSON SAWMILL SPRING	UTAH14009	MEADOW TOWN WATER SYSTEM
WS002	LONE CEDAR SPRING	UTAH14009	MEADOW TOWN WATER SYSTEM
WS004	FISSURE SPRING	UTAH14009	MEADOW TOWN WATER SYSTEM
WS005	DICKEY SPRINGS	UTAH14009	MEADOW TOWN WATER SYSTEM

Utah Department of Environmental Quality

Division of Drinking Water

Monitoring Schedule

Run Date:
08/04/2011 12:10 pm